

From: [Kenny Blake](#)
To: [Mistry, Jatin](#)
Cc: [Rodriguez, Jose](#); [Ngo, Kim](#); [Biggs, Tonia](#); [Baker, JohnE](#); [Georgina Atencio](#); [Bresnahan, Meaghan](#)
Subject: RE: Additional Chlorine Sampling for Cochiti Lake Distribution
Date: Friday, September 15, 2017 12:26:15 PM

Jatin – Attached is John's supporting documentation of the readings I sent in the email. I noticed he had changed the vertical listing of his sheet and I had recorded some of 9/14's readings with the wrong address. You can see both 9/14 and 9/15 respective readings with the correct address on this attachment.

It appears the adjustment made to the dosage is starting to be reflected in higher residuals – kb

Friday 09152017

Site 1 East Site – Cochiti Minimart 1405 Cochiti Highway - .54
Site 2 Golf course kitchen (farthest northern point) - .58
Site 3 Center of Town – 6515 Hoochaneetsa - .57
Site 4 Western site – 5902 Koorani - .61
Site 5 Location North of Well # 1 – 6507 Horseshoe - .53
Site 6 South Site 6459 Vooscane - .62

From: Mistry, Jatin [mailto:Mistry.Jatin@epa.gov]
Sent: Friday, September 15, 2017 10:08 AM
To: Kenny Blake
Cc: Rodriguez, Jose; Ngo, Kim; Biggs, Tonia; Baker, JohnE; Georgina Atencio; Bresnahan, Meaghan
Subject: RE: Additional Chlorine Sampling for Cochiti Lake Distribution

Hi Mr. Blake,

Thank you for sharing the chlorine residuals for Thursday. I see that the center of town residual has increased over 10 parts since Wednesday. Let us now see if this increased residual makes its way to the outer parts of the system. Please submit the residuals for Friday when you have time.

Thank You,
Jatin

Jatin H. Mistry
US EPA Region 6
Drinking Water Section
1445 Ross Avenue (6WQ-SD)
Dallas, TX 75202
(Voice) 214-665-7483
(Fax) 214-665-2191
mistry.jatin@epa.gov

From: Kenny Blake [<mailto:kenny@cochitigolfclub.com>]
Sent: Friday, September 15, 2017 8:02 AM
To: Baker, JohnE <Baker.JohnE@epa.gov>; Georgina Atencio <georgina@cochitigolfclub.com>
Cc: Rodriguez, Jose <Rodriguez.Jose@epa.gov>; Ngo, Kim <Ngo.Kim@epa.gov>; Mistry, Jatin <Mistry.Jatin@epa.gov>; Biggs, Tonia <Biggs.Tonia@epa.gov>
Subject: RE: Additional Chlorine Sampling for Cochiti Lake Distribution

Thursday 09142017

Site 1 East Site – Cochiti Minimart 1405 Cochiti Highway - .55
Site 2 Golf course kitchen (farthest northern point) - .51
Site 3 Center of Town – 6515 Hoochaneetsa - .60
Site 4 Western site – 5902 Koorani - .59
Site 5 Location North of Well # 1 – 6507 Horseshoe - .60
Site 6 South Site 6459 Vooscane - .53

From: Kenny Blake
Sent: Wednesday, September 13, 2017 1:56 PM
To: 'Baker, JohnE'; Georgina Atencio
Cc: 'Rodriguez, Jose'; 'Ngo, Kim'; 'Mistry, Jatin'; 'Biggs, Tonia'
Subject: RE: Additional Chlorine Sampling for Cochiti Lake Distribution

Here is the results of Wednesday's testing: - kb

Wednesday September 13, 2017

Site 1 East Site – Cochiti Minimart 1405 Cochiti Highway - .51
Site 2 Golf course kitchen (farthest northern point) - .48
Site 3 Center of Town – 6515 Hoochaneetsa - .51
Site 4 Western site – 5902 Koorani - .55
Site 5 Location North of Well # 1 – 6507 Horseshoe - .48
Site 6 South Site 6459 Vooscane - .53

From: Kenny Blake
Sent: Tuesday, September 12, 2017 10:44 AM
To: 'Baker, JohnE'; Georgina Atencio
Cc: 'Rodriguez, Jose'; 'Ngo, Kim'; 'Mistry, Jatin'; 'Biggs, Tonia'
Subject: RE: Additional Chlorine Sampling for Cochiti Lake Distribution

Here is the results of today's testing: Attached is a picture of John's worksheet today - kb

Tuesday September 12, 2017

Site 1 East Site – Cochiti Minimart 1405 Cochiti Highway - .54

Site 2 Golf course kitchen (farthest northern point) - .50
Site 3 Center of Town – 6515 Hoochaneetsa - .49
Site 4 Western site – 5902 Koorani - .57
Site 5 Location North of Well # 1 – 6507 Horseshoe - .48
Site 6 South Site 6459 Vooscane - .53

From: Kenny Blake
Sent: Tuesday, September 12, 2017 7:28 AM
To: 'Baker, JohnE'; Georgina Atencio
Cc: 'Rodriguez, Jose'; 'Ngo, Kim'; 'Mistry, Jatin'; 'Biggs, Tonia'
Subject: RE: Additional Chlorine Sampling for Cochiti Lake Distribution

Here is the results of yesterday's testing: Attached is a picture of John's worksheet - kb

Monday September 11, 2017

Site 1 East Site – Cochiti Minimart 1405 Cochiti Highway - .59
Site 2 Golf course kitchen (farthest northern point) - .51
Site 3 Center of Town – 6515 Hoochaneetsa - .55
Site 4 Western site – 5902 Koorani - .66
Site 5 Location North of Well # 1 – 6507 Horseshoe - .44
Site 6 South Site 6459 Vooscane - .61

From: Kenny Blake
Sent: Friday, September 08, 2017 1:09 PM
To: 'Baker, JohnE'; Kenny Blake; Georgina Atencio
Cc: Rodriguez, Jose; Ngo, Kim; Mistry, Jatin; Biggs, Tonia
Subject: RE: Additional Chlorine Sampling for Cochiti Lake Distribution

Here are the Official Sites and Test Results regarding Chlorine:

Site 1 East Site – Cochiti Minimart 1405 Cochiti Highway - .38
Site 2 Golf course kitchen (farthest northern point) - .38
Site 3 Center of Town – 6515 Hoochaneetsa - .51
Site 4 Western site – 5902 Koorani - .53
Site 5 Location North of Well # 1 – 6507 Horseshoe - .29
Site 6 South Site 6459 Vooscane - .54

Thanks and please let us know if it is OK to lift the Water Boil Advisory – kb

Kenny Blake PGA | Cochiti Community Development Corporation
Chief Executive Officer

5200 Cochiti Highway
Cochiti Lake, NM 87083
T (505) 465-2210 x 11 | **F** (505) 465-0160
kenny@cochitigolfclub.com
www.cochitigolfclub.com | *Professional. Precision. Performance.*

CONFIDENTIALITY NOTICE

This e-mail and any attachments are for the sole use of the intended recipients and contain information that may be confidential or legally privileged. If you have received this e-mail in error, please notify the sender by reply e-mail and delete the message. Any disclosure, copying, distribution, or use of this communication by someone other than the intended recipient is prohibited.

From: Baker, JohnE [<mailto:Baker.JohnE@epa.gov>]
Sent: Friday, September 08, 2017 11:10 AM
To: Kenny Blake
Cc: Rodriguez, Jose; Ngo, Kim; Mistry, Jatin; Biggs, Tonia
Subject: RE: Additional Chlorine Sampling for Cochiti Lake Distribution

Thanks for the update Kenny. Please remember to provide a description and location of each sample site.

John

John E. Baker
Tribal Drinking Water Section, 6WQ-SD
Work (214) 665-7542
Cell (817) 946-9755
Fax (214) 665-2191
Baker.JohnE@epa.gov
Senior Environmental Employment Program

From: Kenny Blake [<mailto:kenny@cochitigolfclub.com>]
Sent: Friday, September 08, 2017 12:00 PM
To: Baker, JohnE <Baker.JohnE@epa.gov>
Cc: Rodriguez, Jose <Rodriguez.Jose@epa.gov>; Ngo, Kim <Ngo.Kim@epa.gov>; Mistry, Jatin <Mistry.Jatin@epa.gov>; Biggs, Tonia <Biggs.Tonia@epa.gov>
Subject: RE: Additional Chlorine Sampling for Cochiti Lake Distribution

Thanks – I'll have the results from 5 or 6 sites here soon - kb

From: Baker, JohnE [<mailto:Baker.JohnE@epa.gov>]
Sent: Thursday, September 07, 2017 2:15 PM
To: Kenny Blake
Cc: Rodriguez, Jose; Ngo, Kim; Mistry, Jatin; Biggs, Tonia
Subject: Additional Chlorine Sampling for Cochiti Lake Distribution

Kenny, enjoyed talking with you today.

Before EPA Region 6 can allow the (BWA) Boil Water Advisory to be lifted we are requesting five (5) chlorine level samples from distribution. This additional sampling will insure acceptable Cl levels in the water provided to the residents.

The locations that are best to be sampled for are:

- Site 1 New Visitors Center (farthest southern point)
- Site 2 Golf course kitchen (farthest northern point)
- Site 3 Center of Town
- Site 4 Farthest western site
- Site 5 Location North of Well # 1

Please provide the Cl results to us along with a detailed description of each sample site. Your continued efforts and commitment to address water quality issues along with correcting Well #1 and Well # 2 significant deficiencies are greatly appreciated. Please call if you have any question or concerns.

Regards, John

John E. Baker
Tribal Drinking Water Section, 6WQ-SD
Work (214) 665-7542
Cell (817) 946-9755
Fax (214) 665-2191
Baker.JohnE@epa.gov
Senior Environmental Employment Program